

SAFE DRINKING WATER AND SANITARY CONDITION
CERTIFICATE

No. 379Date: 23/8/2023

It is certified that an inspection team headed by Anuj Kumar Sinha
Sub divisional officer chas (Name of Officers
with designation) from Drinking Water & Sanitation Division, Chas (Name of
Department/Office) inspected the DHRUV AYUSHMAN VATS INTERNATIONAL
SCHOOL, CHIKSIA, CHAS, BOKARO (Name & Address of
the School) on 22-8-2023 and found that the DHRUV AYUSHMAN VATS INTL
NATIONAL SCHOOL (Name of school) has safe
drinking water facilities for the students and members of staff of the institution and is maintaining
the hygienic sanitation condition in the school building & the campus as per the norms
prescribed by the Central/State/U.T Govt.

The above valid for a period of 1 YearSignature with Seal: Anuj Kumar Sinha
23/8/2023

Name

: Anuj Kumar Sinha

Designation

: Sub divisional officer chas

To

SECRETARYDHRUV AYUSHMAN VATS INTERNATIONAL SCHOOLCHIKSIA, CHAS, BOKARO

(Name & Address of the Institution)

PrincipalDhruv Ayushman Vats International School
Chiksia, Chas (Bokaro)SecretaryDhruv Ayushman Vats International School
Chiksia, Chas (Bokaro)S.D.O.
D.W. & S. SUB-DIV
CHAS
23/8/2023



17

District Level Water Testing Laboratory, Chas
ITI More Chas, PIN-827013
Email:dlwtlchas@gmail.com

Test Report

Report No:	DL.WTL/TW/ 16	Issue Date :-16.08.2023
Issued To: (Name & Address of Customer)	DHRUV AYUSHMAN VATS INTERNATIONAL SCHOOL CHIKSIA, CHAS BOKARO	Sample Quantity: - 1 liter
Date of Start Analysis: -	01.08.2023	Sampling: Done by laboratory
Date of Completion Analysis: -	02.08.2023	Sample Received Date:- 01.08.2023 Environmental Condition- Tem - 26.8C, Hum. 58 RH

Sl. No.	Parameter	Unit	Result	Method Reference	Specification as per BIS - 10500:2012 (Second Revision) Amendment - June 2015	
					Acceptable Limit	Permissible Limit (In Absence of Alternate source)
1	pH	-	7.5	APHA 23 rd Edition 2017-4500-H* B, (Electrometric Method)	6.5 - 8.5	No relaxation
2	Turbidity	NTU	0.24	APHA-23 rd Edition 2017-2130-B, (Nephelometric method)	1	5
3	Total Dissolved Solids	mg/L	156	APHA 23 rd Ed.2017-2540 C, (Total Dissolved Solids Dried at 180°C)	500	2000
4	Chloride (as Cl)	mg/L	19.99	APHA-23 rd Edition 2017-4500 Cl- B, (Argentometric method)	250	1000
5	Total Hardness as CaCO ₃	mg/L	108	APHA-23 rd Edition 2017-2340-C (EDTA Titrimetric method)	200	600
6	Total Alkalinity as CaCO ₃	mg/L	124	APHA-23 rd Edition 2017-2320-B, (Titration Method)	200	600
7	Calcium as Ca ⁺	mg/L	24.04	APHA-23 rd Edition 2017-3500-Ca-B, (EDTA Titrimetric Method)	75	200
8	Magnesium as Mg ⁺	mg/L	10.69	APHA-23 rd Edition 2017-3500-Mg-B, (Calculation Method)	30	100
9	Fluoride as F	mg/L	0.75	APHA 23 rd Ed.2017-4500 F- C, (Ion selective electrode method)	1.0	1.50
10	Colour	HU	05	Visual comparison	5	15
11	Odour	-	Agreeable	Observation	Agreeable	Agreeable
12	Taste	-	Agreeable	Observation	Agreeable	Agreeable

Notes: -

- The results listed refer only to the tested sample and applicable parameters
- This report, in full or in part, shall not be used for advertising or as evidence in any court of law
- This report cannot be reproduced, except when in full, without the written permission of the Lab In-charge
- All disputes are subjected to the Bokaro Jurisdiction.
- BDL-Below Detection Limit

Mukul Rawani
16/08/2023
Quality Manager
District Level Water Testing Laboratory
D.W. & S. Division, Chas

MUKUL RAWANI
Authorised Signatory

-End of the Report

Smit
Secretary

Dhruv Ayushman Vats International School
Chiksia, Chas (Bokaro)

Principal

Dhruv Ayushman Vats International School
Chiksia, Chas (Bokaro)

OFFICE OF THE EXECUTIVE ENGINEER,
BUILDING CONSTRUCTION DEPARTMENT,
BUILDING DIVISION BOKARO.

Letter No...7/5...

Dated...22/08/2023

CERTIFICATE OF SAFETY

Name of the School :- DHRUV AYUSHMAN VATS INTERNATIONAL SCHOOL

Village, Town and District in Which the school is situated :- Chiksia, Chas, Dist-Bokaro.

Full postal address of the School :- Chiksia, Chas, Dist-Bokaro.

Name of the occupier of the School :- DHRUV AYUSHMAN VATS INTERNATIONAL SCHOOL

I, certify that I have inspected The Dhruv Ayushman Vats International School building at Chiksia, Chas, Dist-Bokaro, on 21.08.2023 and examined various parts including the structure as shown in the site. I am of opinion that the building has been constructed in accordance with the approved design. School building structure is structurally sound for use.

Your's Faithfully

[Signature]
22/08/2023

Executive Engineer,
Building Division, Bokaro.
कार्यपालक अभियन्ता
भवन प्रमण्डल, बोकारो

[Signature]
22/08/23

[Signature]
Principal

Dhruv Ayushman Vats International School
Chiksia, Chas (Bokaro)

[Signature]
Secretary

Dhruv Ayushman Vats International School
Chiksia, Chas (Bokaro)